



Certificate of Fire Extinguisher Compliance

This Certificate confirms that Firecheck Services (UK) Ltd.
Have completed the maintenance service/installation/commissioning of the fire equipment listed
below to British Standards B.S.5306 Pt3 & Pt8; 2023.

Company Name: **BARNWOOD SCOUT CAMP**

Site Address:

**LEEK OLD ROAD
MACCLESFIELD
SK11 0RB**

Fire extinguisher Classifications:

Class A: Wood, paper textiles fires

Class B: Flammable Liquids fires

Class C: Gaseous fires

Class D: Metal fires

Class F: Cooking oil fires



Live electrical fires

Service Sheet No: **18818**

Certificate Valid From Period:

September 2025-2026

The Certificate is valid for approximately 12 months from month of service + or - the month.

Extinguishers that conform to B.S.5306 Pt3; 2017 & Part 8: 2023 Recorded below:

It is recommended that regular inspection of all fire extinguishers be carried out by the user representatives at regular intervals.
Inspections should ensure that the appliances are in their proper positions and have not been discharged, lost pressure or suffered obvious damage.
These inspections should be carried out at least weekly. If there are signs of damage or if an extinguisher has been used or part used contact
Firecheck services (UK) Ltd immediately.

Water	Foam	Co2	Dry Powder	Multi-Chem	Wet Chemical	Water Mist	Fire Blanket
Class A	Class A & B	Class B & Live Electrics	Class A,B,C, Electrical	Class A, B, & F	Class A & F	Class A, F & Electrical	
18	2	9	✓	✓	✓	✓	5

**** Caution **** B.S. 5306 Pt.8: Dry Powder extinguishers are not advised for indoor use. Using Dry Powder extinguishers indoors can cause asphyxiation and problems during evacuation due to loss of visibility. Unless mitigated by a Health & Safety Risk Assessment. ******

Additional work/action is considered necessary, recommendations and requirements have been recorded on the service sheet that has been issued. Tick Box if applicable: ☐

Firecheck Services (UK) Ltd
Unit 5 Kings Business Park
Great Barr, Birmingham
B44 9HP
www.firecheckservices.co.uk
info@firecheckservices.co.uk

Tel: 0121 605 7049

The UK
Fire Association

