



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

Barnwood Camp Hall 2025

Certificate No: JW1040

Engineers Details

Trading Title: John Worth Ltd

Address: John Worth Ltd James House
Calamine Street
Macclesfield
Post Code: SK11 7HU

Gas Safe No: 9605 Telephone No: 01625 423569

Installation Details

Installation Address: Barnwood Scout Camp
Barnwood Scout Camp
Leek Old Road, Macclesfield
Cheshire
Post Code: SK11 0RB

Telephone No: 01260226359

Client Details

Client Address: Barnwood Scout Camp
Barnwood Scout Camp
Leek Old Road, Macclesfield
Cheshire
Post Code: SK11 0RB

Telephone No: 01260226359

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	Combustion LOW (CO2% or CO/CO2 ratio)	Combustion HIGH (CO2% or CO/CO2 ratio)	Heat Input (KW) or Operating Pressure (Mbar)	CO Reading (ppm)	Appliance Inspected (YES/NO/NA/IO) <small>(IO = Visual Inspection Only)</small>	Flue Type (OF/RS/FL)	Landlords Appliance (YES/NO/NA)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Camp Hall Kitchen	Combi boiler	Vaillant	C PRO 24 VUW 246/3-3	0.0001	0.0010	33 mb	94	YES	RS	YES	YES	YES	YES	PASS	YES	YES
2																	
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible: YES Gas Tightness Satisfactory: YES

Gas Installation Pipework Visual Inspection Satisfactory: YES

Number of Appliances Tested: Equipotential Bonding: YES

NEXT INSPECTION DUE ON OR BEFORE: Installation Pass: YES

CO Alarm fitted & working? YES Smoke alarm fitted & working? YES

Signatures

Report Issued By:

Name: Jack Whitehead

Signed:

Date: Fri-07-11-2025

Report Received By:

Name: key

Signed:

Date: Fri-07-11-2025

Gas ID Number: 5424743