



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

Barnswood Marsden Chalet 2025

Certificate No: JW1041

### Engineers Details

Trading Title: John Worth Ltd

Address: John Worth Ltd James House  
Calamine Street  
Macclesfield  
Post Code: SK11 7HU

Gas Safe No: 9605 Telephone No: 01625 423569

### Installation Details

Installation Address: Barnswood Scout Camp  
Barnswood Scout Camp  
Leek Old Road, Macclesfield  
Cheshire  
Post Code: SK11 0RB

Telephone No: 01260226359

### Client Details

Client Address: Barnswood Scout Camp  
Barnswood Scout Camp  
Leek Old Road, Macclesfield  
Cheshire  
Post Code: SK11 0RB

Telephone No: 01260226359

### Appliance Details

### Inspection Details

	Location	Appliance Type	Make	Model	Combustion LOW (CO2% or CO/CO2 ratio)	Combustion HIGH (CO2% or CO/CO2 ratio)	Heat Input (KW) or Operating Pressure (Mbar)	CO Reading (ppm)	Appliance Inspected (YES/NO/NA/IO) <small>(IO - Visual Inspection Only)</small>	Flue Type (OF/RS/FL)	Landlords Appliance (YES/NO/NA)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	en Chalet Store Cup	Combi boiler	Vaillant	C PRO 24 VUW 246/3-3	0.0001	0.0009	31.5 mb	92	YES	RS	YES	YES	YES	YES	PASS	YES	YES
2																	
3																	
4																	
5																	

### Faults/Notes

### Remedial Work Taken

### Warning Notice Fixed

1	Flue under 2m from ground without a flue guard	Advise landlord to get an appropriate flue guard fitted	NA
2			
3			
4			
5			

Emergency Control Valve Accessible:  YES  NO

Gas Tightness Satisfactory:  YES  NO

Gas Installation Pipework Visual Inspection Satisfactory:  YES  NO

Number of Appliances Tested:  Equipotential Bonding:  YES  NO

NEXT INSPECTION DUE ON OR BEFORE:  Installation Pass:  YES  NO

CO Alarm fitted & working?  YES  NO Smoke alarm fitted & working?  YES  NO

### Signatures

Report Issued By:

Name: Jack Whitehead

Signed:

Date: Fri-07-11-2025

Report Received By:

Name: key

Signed:

Date: Fri-07-11-2025

Gas ID Number: 5424743